

Annual Drinking Water Quality Report for 2013
Village of Earlville
8 North Street
Public Water Supply ID# NY2602374

INTRODUCTION

To comply with State regulations, [the Village of Earlville](#) will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. [Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard.](#) This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact Mark Tucker, Village of Earlville at (315) 691-2353. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled village board meetings. The meetings are held on the second Tuesday of each Month at 7:30 PM at the Village Offices located at North Main Street, Earlville, New York 13332.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves approximately 790 people through 443 service connections. Our water source is groundwater drawn from two 130+/- foot deep drilled wells that are located off East Main Street. The water is disinfected with sodium hypochlorite prior to distribution.

NEW YORK STATE DEPARTMENT OF HEALTH SOURCE WATER ASSESSMENT PROGRAM:

The NYSDOH has completed a source water assessment for this system based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water, it **does not mean** that the water delivered to consumers is, or will become contaminated. See section "Are There Contaminants in our Drinking Water?" for a list of contaminants that have been detected. The source water assessment provides resource managers with additional information for protecting source water into the future.

The public water supply for the Village of Earlville is served from 2 wells. The source water assessment has rated these wells as having a high susceptibility rating for nitrates, and a medium-high susceptibility to industrial solvents, and other industrial contaminants, and nitrates. These ratings are due primarily to the close proximity of permitted discharge facilities (industrial/commercial facilities that discharge wastewater into the environment and are regulated by the state and/or federal government) and land use practices (pastures) identified within the assessment area. Based on submitted data, the well field may be prone to flooding. Please note that, while the source water assessment rates the wells as being susceptible to microbials, the water is disinfected to ensure that the finished water delivered into your home meets the New York State drinking water standards for microbial contamination.

County and state health departments will use this information to direct future source water protection activities. These may include water quality monitoring, resource management, planning, and education programs. If you

have any questions regarding the Source Water Assessment or if you would like to review the Source Water Assessments in our office please feel free to contact the Madison County Department of Health at 315-366-2526.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: [total coliform](#), [turbidity](#), [inorganic compounds](#), [nitrate](#), [nitrite](#), [lead and copper](#), [volatile organic compounds](#), [total trihalomethanes](#), [haloacetic acids](#), [radiological](#) and [synthetic organic compounds](#). The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Range) (Avg/Max)	Unit of Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination

Inorganic Contaminants

Barium	No	12/27/11	0.140	Mg/l	2.000	2.000	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Lead (2)	No	9/4/11	3.0 Range (1.0 – 14.0)	Ug/l	0	AL = 15	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (1)	No	9/4/11	0.210 Range (0.022 – 0.320)	Mg/l	1.300	AL = 1.300	Corrosion of household plumbing systems; Erosion of natural deposits
Iron (6) Well #1 Well #2	No No	11/12/13 4/12/12	52 47	Ug/l Ug/l	N/A	300	Naturally occurring
Manganese Well #1 Well #2	No No	11/12/13 11/12/13	120 110	Ug/l Ug/l	N/A	300	Naturally occurring; Indicative of landfill contamination.

Inorganic Contaminants

Sodium (3) Well#1 Well#2	No No	9/02	2.4 2.2	Mg/l	N/A	(See Health effects)	Naturally occurring; Road salt; Water softeners; Animal waste.
Chloride Well#1 Well#2	No No	9/02	3.0 3.0	Mg/l	N/A	250	Naturally occurring or indicative of road salt contamination.
Turbidity (5)	No	11/01/05	3.0	NTU	N/A	5.0	Soil Runoff
Zinc Well#2	No	9/02	0.03	Mg/l	N/A	5	Naturally occurring; Mining waste.

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit of Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
-------------	------------------	----------------	----------------------------------	---------------------	------	----------------------------------	--------------------------------

Disinfection By-Products

Total Trihalo-methanes	No	8/24/2010	3.2	Ug/l	N/A	80	By-product of drinking water disinfection needed to kill harmful organisms. TTHMs are formed when source water contains large amounts of organic matter
------------------------	----	-----------	-----	------	-----	----	---

Radioactive Contaminants

Gross Beta (4)	No	3/17/08 – 12/16/08 Composite	3.1	pCi/l	0	50	Decay of natural deposits and man-made emissions
Gross Alpha	No	12/00	1.0	pCi/l	0	15	Erosion of natural deposits

Footnotes:

1 – The level presented represents the 90th percentile of the 10 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, ten samples were collected at your water system and the 90th percentile value was 0.210 mg/l. The action level for copper was not exceeded at any of the sites tested.

2 – The level presented represents the 90th percentile of the 10 samples collected. The action level for lead was not exceeded at any of the 10 sites tested.

3 – Water containing more than 20 mg/l of sodium should not be used for drinking by individuals on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by individuals on moderately restricted sodium diets

4 – The state considers 50 pCi/l to be the level of concern.

5 – Turbidity is a measure of the cloudiness of the water. State regulations require that turbidity must always be below 5 NTU.

6 -Iron has no health effects. At 1,000 ug/l a substantial number of people will note the bitter astringent taste of iron. Also, at this concentration, it imparts a brownish color to laundered clothing and stains plumbing fixtures with a characteristic rust color. Staining can result at levels of 50 ug/l, lower than those detectable to taste buds. Therefore, the MCL of 300 ug/l represents a reasonable compromise as adverse aesthetic effects are minimized at this level. Many multivitamins may contain 3,000 or 4,000 micrograms of iron per capsule.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Nephelometric Turbidity Unit (NTU): A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

N/A: Not applicable

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the [Madison County Health Department](#) at 315-366-2526.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State. We are required to present the following information on lead in drinking water:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women, infants, and young children. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. [The Village of Earlville](#) is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2013, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements. The Village was found to be in violation of Subpart 5-1.31 of the State Sanitary Code, which states that the Village must develop and implement a cross connection control program to protect the water system. We are currently developing a cross connection control plan for the Village, with assistance from the Madison County Department of Health.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.